



## WESTPORT, CONNECTICUT

### DEPARTMENT OF PUBLIC WORKS

TOWN HALL, 110 MYRTLE AVENUE  
WESTPORT, CONNECTICUT 06880  
(203) 341 1120

### MEMORANDUM

**Date:** 07/01/2020

**To:** Conservation Commission

**From:** Edward Gill, Engineer II

**Re:** 20 Webb Road

#### Reference Materials Reviewed:

- Plan prepared by Grumman Engineering, L.L.C. entitled "Drainage Improvement Plan," dated 01/09/2020 as revised to 06/30/2020.

Dear Conservation Commission,

Our office has reviewed the proposed activity as depicted by the above referenced documents. The plan depicts the removal and relocation of the illegal 4" PVC pipe discharging in the wetlands. The subject activity consists of relaying the pipe such that the discharge shall be 30' from the northern property line while maintaining the same invert elevation. Together with the proposed plunge pool sized to slow the water discharging from this pipe, this design satisfies the Engineering Department requirements for this violation.

Per this review, this item requires no further submissions. While the granting of this approval is at the discretion of the Commission, we find no issues in our review that would preclude such action.

Please contact me should you have any questions regarding the above items.

Thank you,

A handwritten signature in blue ink, appearing to read "Edward Gill".

Edward Gill,  
Engineering Department